

Certificate of Constancy of performance

0051 – CPR – 0222

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

CONTROL AND INDICATING EQUIPMENT FOR FIRE DETECTION AND FIRE ALARM SYSTEMS WITH POWER SUPPLY INTEGRATED

Model: SmartLight/S

Trademark: INIM ELECTRONICS

Other information: see ANNEX

Produced by:

INIM ELECTRONICS S.r.l.
Via Fosso Antico
63076 MONTEPRANDONE (AP)

In the manufacturing plant(s):

PI.H000OJ

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-2:1997+A1:2006
EN 54-4:1997 + A1:2002 + A2:2006

under system **1** are applied and that

the product fulfills all the prescribed requirements set out above.

This certificate cancels and replaces the certificate having the same number and issued on 2009-12-11 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.


IMQ
CPR Technical Director
(Eng. V. Baggio)

Milano, 2014-09-22

This certificate was issued by IMQ S.p.A., a notified body according to Regulation 305/2011/EU.
IMQ S.p.A. Identification Number is: 0051.

Mod. 727CPR-ENG/0

ANNEX

0051 – CPR – 0222

The equipment under test is a Control and Indicating equipment type SmartLight/S, used in fire detection and fire alarm systems.

Configuration of Control and Indicating type SmartLight/S:

It is contained in a metallic enclosure with grade IP30. Internally it is fitted with the following main parts:

- N. 1 Main board (PCB n. IN007-R2);
- N. 1 Extinction board trademark INIM ELECTRONICS, type SmartLetLoose/ONE (PCB n. IN015-R1)(optional);
- N. 1 Switching power supply trademark inim ELECTRONICS, type IPS24060G (PCB n. IN124-R3), rated 230 V~ +10% / -15%; 50/60 Hz; 0.5 A, output: 27.6 V — ; 2.1 A;
- N. 2 Allocable batteries, 12 V – 7 Ah

The Control and Indicating Equipment is also provided of the following external devices:

- LCD Repeater trademark INIM ELECTRONICS type SmartLetUSee/LCD (PCB n. IN002-Rev. 1) (optional, up to 4 maximum);
- LCD Repeater trademark INIM ELECTRONICS type SmartLetUSee/LCD-Lite (PCB n. IN002-Rev. 1) (optional, up to 4 maximum).

Technical characteristic:

- Number of zones: 16 (32 detectors and/or manuals call point for each zone up to 64 maximum);
- hardware identification main board: Renesas, R5F21258SNFP;
- firmware identification main board: FWIN1ASLGGAA01 Rev. 2.04

List of optional functions with requirements:

- 7.8 Output to fire alarm device;
- 7.9 Output to fire alarm routing equipment;
- 7.11 Delay to outputs;
- 7.12 Co-incidence detection, Type A;
- 8.3 Fault signals from points;
- 10 Test condition.

VS